PUBLIC HEALTH ENGINEERING DEPARTMENT

SUB DIVISION WATER TESTING LABORATORY ,Hansi

PHED Haryana

Website :- https://phedharyana.gov.in/

Subject : **Bacteriological Examination Report of Water Samples**

Circle **Hisar Circle** Division **Hansi PHED** Sub Division **Hansi PHESD No. 1**

S.No.	Tested Parameter *	Result (MPN) **	Protocol Used	Potable / Not Potable
Memo No :- 658, Date :- 14/09/2026				
1	**Sample ID:-**HSI/01798/9/2026 **/Sender :** Hansi PHESD No. 1 **,Location :** , GMSSS School Sisai Kalirawan, **Analysis Start/End Date:** 11/09/2026 / 14/09/2026, **GPS Coordinates:** 29.178439 /76.008659			
	Total Coliform per 100 ml	0	IS 15185:2016/APHA 9223B-2023/APHA 9221 B & C	Potable

Abstract Report of Bacteriological Examination Report of Water Sample

Total Sample	Potable	Not Potable
1	1	0

* Requirement (Acceptable Limit) : Shall not be detectable in any 100 ml sample

** MPN (Most Probable Number) Per 100 ML.

Remarks :-

* The Results Given above are related to the sample as received and tested in Hansi lab.
* The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
* The test report can't be used for any publicity or any legal purpose.
* Reliability of water sample sample lies with sender/collector of water sample.

Total Dissolved solids ⇒ 330 mg/Lt

Rajkumar , Nikita

Sample analyzed by :

KANCHAN BISHNOI,CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
SUB DIVISION WATER TESTING LABORATORY, HANSI
email:-chemist.hisar@phedharyana.gov.in

----------WATER IS LIFE,SAVE IT----------

Scanned with CamScanner